

# **DRINKING WATER NOTICE**

## **Unregulated Contaminant Monitoring Rule (UCMR) Reporting Requirement for Columbus City Utilities**

Columbus City Utilities collected samples under the U.S. EPA Unregulated Contaminant Monitoring Rule (UCMR) for 29 PFAS compounds and Lithium.

This monitoring is conducted in compliance with reporting of the data requirements to determine what, if any additional compounds may need to be regulated in drinking water in the future.

We collected finished water samples July 16, 2024 and January 14, 2025. These results are found in the report following this notice.

If you have additional questions, you may contact our office at 812-372-8861.

**UNREGULATED CONTAMINANT MONITORING RULE 5 RESULTS**

| Analyte<br>EPA Method 533                                | Water Plant 1              |                            | Water Plant 2              |                            |
|----------------------------------------------------------|----------------------------|----------------------------|----------------------------|----------------------------|
|                                                          | 7/16/24<br>Results<br>ug/L | 1/14/25<br>Results<br>ug/L | 7/16/24<br>Results<br>ug/L | 1/14/25<br>Results<br>ug/L |
| 11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid      | <0.0047                    | <0.0050                    | <0.0050                    | <0.0050                    |
| 1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)      | <0.0047                    | <0.0050                    | <0.0050                    | <0.0050                    |
| 1H,1H,2H,2H-Perfluorodecane sulfonic acid (4:2 FTS)      | <0.0028                    | <0.0030                    | <0.0030                    | <0.0030                    |
| 1H,1H,2H,2H-Perfluorodecane sulfonic acid (6:2 FTS)      | <0.0047                    | <0.0050                    | <0.0050                    | <0.0050                    |
| 4,8-Dioxa-3H-Perfluorononanoic acid (ADONA)              | <0.0028                    | <0.0030                    | <0.0030                    | <0.0030                    |
| 9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid       | <0.0019                    | <0.0020                    | <0.0020                    | <0.0020                    |
| Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)           | <0.0047                    | <0.0050                    | <0.0050                    | <0.0050                    |
| Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)               | <0.0190                    | <0.0200                    | <0.0200                    | <0.0200                    |
| Perfluoro(2-ethoxyethane)sulfonic acid (PFEEESA)         | <0.0028                    | <0.0030                    | <0.0030                    | <0.0030                    |
| Perfluoro-3-methoxypropanoic acid (PFMPA)                | <0.0038                    | <0.0040                    | <0.0040                    | <0.0040                    |
| Perfluoro-4-methoxybutanoic acid (PFMBA)                 | <0.0028                    | <0.0030                    | <0.0030                    | <0.0030                    |
| Perfluorobutanesulfonic acid (PFBS)                      | 0.0031                     | 0.0048                     | 0.0063                     | 0.0096                     |
| Perfluorobutanoic acid (PFBA)                            | 0.0061                     | 0.0083                     | 0.0059                     | 0.0092                     |
| Perfluorodecanoic acid (PFDA)                            | <0.0028                    | <0.0030                    | <0.0030                    | <0.0030                    |
| Perfluorododecanoic acid (PFDoA)                         | <0.0028                    | <0.0030                    | <0.0030                    | <0.0030                    |
| Perfluoroheptanesulfonic acid (PFHpS)                    | <0.0028                    | <0.0030                    | <0.0030                    | <0.0030                    |
| Perfluoroheptanoic acid (PFHpA)                          | <0.0028                    | <0.0030                    | <0.0030                    | <0.0030                    |
| Perfluorohexanesulfonic acid (PFHxS)                     | <0.0028                    | <0.0030                    | <0.0030                    | <0.0030                    |
| Perfluorohexanoic acid (PFHxA)                           | <0.0028                    | <0.0030                    | 0.0042                     | 0.0083                     |
| Perfluorononanoic (PFNA)                                 | <0.0038                    | <0.0040                    | <0.0040                    | <0.0040                    |
| Perfluorooctanesulfonic acid (PFOS)                      | <0.0038                    | <0.0040                    | <0.0040                    | <0.0040                    |
| Perfluorooctanoic acid (PFOA)                            | <0.0038                    | <0.0040                    | <0.0040                    | <0.0040                    |
| Perfluoropentanesulfonic acid (PFPeS)                    | <0.0038                    | <0.0040                    | <0.0040                    | <0.0040                    |
| Perfluoropentanoic acid (PFPeA)                          | 0.0105                     | 0.0163                     | 0.0067                     | 0.014                      |
| Perfluoroundecanoic acid (PFUnA)                         | <0.0019                    | <0.0020                    | <0.0020                    | <0.0020                    |
| Analyte<br>EPA Method 537.1                              | 7/16/24<br>Results<br>ug/L | 1/14/25<br>Results<br>ug/L | 7/16/24<br>Results<br>ug/L | 1/14/25<br>Results<br>ug/L |
|                                                          |                            |                            |                            |                            |
| N-ethylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)  | <0.0050                    | <0.0050                    | <0.0050                    | <0.0050                    |
| N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA) | <0.0060                    | <0.0060                    | <0.0060                    | <0.0060                    |
| Perfluorotetradecanoic acid (PFTA)                       | <0.0080                    | <0.0080                    | <0.0080                    | <0.0080                    |
| Perfluorotridecanoic acid (PFTrDA)                       | <0.0070                    | <0.0070                    | <0.0070                    | <0.0070                    |
| Analyte<br>EPA Method 200.7                              | 7/16/24<br>Results<br>ug/L | 1/14/25<br>Results<br>ug/L | 7/16/24<br>Results<br>ug/L | 1/14/25<br>Results<br>ug/L |
|                                                          |                            |                            |                            |                            |
| Lithium                                                  | <9.00                      | <9.00                      | <9.00                      | <9.00                      |